

Certificate of Conformity

By the product certificate number

No. 2622/0478-K-CER

Issued to

License holder:

Victron Energy B.V.
De Paal 35, 1351 JG Almere, Netherlands

Trademark:



Contract number:

802190

It is certified that the product

Type of product: Inverter/charger with UPS functionality

Models	MultiPlus-II 48/8000/110-100	MultiPlus-II 48/10000/140-100	MultiPlus-II 48/15000/200-100
Rated characteristics			
Rated Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Rated Frequency		50 Hz	
Firmware version	2621554	2627554	2619554
Number of phases		Single Phase (L/N/PE)	
Isolation transformer		Yes	

Is in compliance with the standard requirements

- **Technical regulation 3.3.1 for electrical energy storage facilities.**
Category A. Energy storage facilities up to 125 kW.
Revision 3. Dated on 01st January 2023.

The above-mentioned generating unit is certified according to the SGS internal procedure No. 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on 22nd August 2024.
This certificate is valid until the 22nd August 2029.

Madrid, 22nd August 2024

Daniel Arranz Muñiz
Certification Manager



SGS Tecnos, S.A.U. C/ Trespademe, 29 - 28042 Madrid
This certificate is issued by SGS under its General Conditions for Product Certification at www.sgs.com/terms_and_conditions.
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).
This document cannot be reproduced partially

